

# Certificate of Conformity CE



**CIDEMCO**  
CENTRO DE INVESTIGACION TECNOLÓGICA

Area Anardi, nº 5  
20730 AZPEITIA (Guipúzcoa) SPAIN  
Tel.: + 34 943 816800 – Fax: + 34 943 816074  
Email: [certificacion@cidemco.es](mailto:certificacion@cidemco.es)  
<http://www.cidemco.es>

**NOTIFIED BODY N°: 1239**

## Applicant

TELESCO CONTROL DE PUERTAS, S.L.  
C/ Llobatona,19  
08840 – VILADECANS (Barcelona) SPAIN  
Tel.: + 34 93 635 71 50 / Fax: + 34 93 658 33 53  
E-mail: [info.telesco@telesco.es](mailto:info.telesco@telesco.es)  
[www.telesco.es](http://www.telesco.es)

## Production centre

C/ Llobatona,19  
08840 – VILADECANS (Barcelona) SPAIN

## CERTIFICATE NO.

0800311

## Product Range Certified

**UNIKCOMBI**

## Scope of Certification (Reference)

- A2459S.XX Unikcombi door closer with adjustable pointer, standard force 2 and 4
- A2459T.XX Unikcombi series door closer with adjustable pointer, force 2 and 4 adjustable latch

Where XX: Ag (Silver), Au(Gold), WH(White), BL(Black), BR(Bronze)

COMMENT: As per Schedule A of the EN 1154:1996+ A1:2002 standard, door closers placed on fire/smoke doors:

- should not be equipped with a retaining device, unless it is electromagnetic, and
- should be able to adjust to a force level of 3

## Certification system used

**Sistema 1**

This certification is issued in accordance with Annex ZA of the regulation

UNE-EN 1154:2003 / EN 1154:1996+A1:2002

According to initial tests, the rating for the device is as follows:

3	8	2	1	1	3
(1)	(2)	(3)	(4)	(5)	(6)

Date effective: **15/12/2006**  
Date of last modification: **24/02/2009**  
Valid until: **02/02/2010**  
Serie nº: **080031102**



Angel Lanchas  
Manager

This certificate only covers products whose commercial references, materials and technical data are specified on the technical sheet supplied by the applicant.  
This certificate may be modified, temporarily suspended and withdrawn.